



STATE OF ALASKA  
DEPARTMENT OF  
**COMMERCE**  
COMMUNITY AND  
ECONOMIC DEVELOPMENT

*Bill Walker, Governor*  
*Chris Hladick, Commissioner*  
*Robert M. Pickett, Chairman*

---

Regulatory Commission of Alaska

November 10, 2016

In reply refer to: Tariff Section  
File: TA291-13  
LO #: L1600547

Cory Borgeson  
President & CEO  
Golden Valley Electric Association, Inc.  
P. O. Box 71249  
Fairbanks, AK 99707-1249

Dear Mr. Borgeson:

Golden Valley Electric Association, Inc. (GVEA) filed TA291-13 on September 16, 2016, seeking approval of the revised language governing reset of the Standby Contract Capacity Reset. On November 9, 2016, the Regulatory Commission of Alaska approved Tariff Sheet No. 43.5, filed November 7, 2016, by Golden Valley Electric Association, Inc. in TA291-13.

Enclosed is a validated copy of the approved tariff sheet. The effective date of the tariff sheet is November 14, 2016. Please note that the effective date has been added to the bottom right corner of the tariff sheet.

BY DIRECTION OF THE COMMISSION

Sincerely,

REGULATORY COMMISSION OF ALASKA

Bernie Smith  
Engineering Section Manager

Enclosures

cc: Monica Grassi  
Regulatory Specialist  
Golden Valley Electric Association, Inc.  
P. O. Box 71249  
Fairbanks, AK 99707-1249

RCA No. 13  
Canceling: \_\_\_\_\_

First Revision  
Original

Sheet No. 43.5  
Sheet No. 43.5

**RECEIVED**  
NOV 07 2016

**GOLDEN VALLEY ELECTRIC ASSOCIATION, INC.**

STATE OF ALASKA  
REGULATORY COMMISSION OF ALASKA

**ELECTRIC SERVICE RATES**  
**STANDBY SERVICE**  
**Rate Schedule SB**  
(continued)

Special Provisions (continued):

1) Reset of Standby Contract Capacity:

The Standby Contract Capacity shall reset after each time a Member takes power under this rate schedule for either Backup Power or Scheduled Maintenance Power should the power actually delivered by the Association be in an amount greater than the prior setting of the Standby Contract Capacity. Exceeding the established Standby Contract Capacity will result in the Minimum Term restarting as of the date the Standby Contract Capacity was exceeded. The Standby Contract Capacity shall be reset to the actual maximum amount of capacity delivered to the Member going forward. Costs incurred with the reset will be recovered by the Association through a corresponding change in the Reservation Demand Charge.

T  
N,T  
N,T

2) Service Measurement:

In such cases when a Member combines Standby Service with Electric Service under a full service tariff, both tariffs will be effective with the full service tariff measured first through the meter.

3) Power Factor Requirements:

The Member shall maintain an average power factor between the limits of 90% leading and 90% lagging. When the lagging power factor is less than 90%, the Demand Charge and Reservation Charge shall be increased in the ratio that 90% bears to the actual power factor. The Association may require the Member to install power factor corrective equipment if the average power factor is below 85%.

Tariff Advice No. TA291-13

Effective: November 14, 2016

Issued by: Golden Valley Electric Association, Inc.

By:  FOR  
Cory R. Borgeson

Title: President & CEO